

# INTERACTION EFFECTS IN MEASUREMENT SYSTEMS

by D. R. Englund

Lewis Research Center  
Cleveland, Ohio

GPO PRICE \$ \_\_\_\_\_

CSFTI PRICE(S) \$ \_\_\_\_\_

Hard copy (HC) 3.00

Microfiche (MF) .65

ff 653 July 65



TECHNICAL PAPER proposed for presentation at

15<sup>th</sup> Annual Cleveland Electronics Conference  
Cleveland, Ohio, April 16-18, 1968

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

N 68-34671

FACILITY FORM 502

(ACCESSION NUMBER)

27

(PAGES)

TMX 6544

(NASA CR OR TMX OR AD NUMBER)

(THRU)

14

(CATEGORY)

E-4415

# INTERACTION EFFECTS IN MEASUREMENT SYSTEMS

by D. R. Englund

Lewis Research Center  
National Aeronautics and Space Administration  
Cleveland, Ohio

## ABSTRACT

Presented is a discussion of the problem of matching an instrument to a system such that a minimum disturbance is generated when the instrument is connected. The concept of loading, as determined by such properties as impedance or stiffness, is used to describe these interaction effects. Practical examples of measurements of electrical quantities, temperature, force, pressure, and flowrate are used as a basis for the discussion.

## INTRODUCTION

A fundamental goal in measurement engineering is that the addition of instrumentation to a physical system shall not disturb the system from its noninstrumented state. Strictly speaking, however, this goal is impossible to achieve, since all sensors draw some power or energy from the system to which they are applied.

The effects caused by such disturbances are twofold; the disturbance can: (1) change the value of the variable being measured, or (2) change the operating characteristics of the system. A simple example of the first effect is the loading caused by a low-resistance voltmeter; the voltage appearing at the terminals where the measurement is to be made is reduced

by an amount which is proportional to the current flowing in the voltmeter. An example of the second effect might be that the addition of test instrumentation to an oscillator circuit may cause the oscillator to stop oscillating or to change the frequency of the oscillator. This effect often results in a meaningless experiment. Effects of the first type are the ones that will be discussed in this paper; they are commonly referred to as loading effects.

Since disturbances caused by instrumentation are unavoidable, what is really meant by the original statement is, then, that the disturbance caused by the addition of instrumentation should:

1. produce a negligible effect, or
2. produce an appreciable effect which
  - a. can be determined, and
  - b. can be corrected for with a negligible uncertainty.

A further characteristic of instrument interaction effects worth noting at this point is that these effects occur throughout a measurement system. Figure 1 illustrates this point. A resistance thermometer is used to measure the temperature of a fluid. The system consists of a sensor, a power supply and signal conditioner, an amplifier, and one or more readout instruments. Interaction problems can arise at the various interconnections in the system as noted on the figure. Many of these problems are made negligible by proper choice of the electrical input and output impedances of the system components. Some of the remaining effects can be corrected by system calibration. The "thermal connection" of the sensor to the experiment is a most important effect and is often overlooked because of its nonelectrical nature. Interaction effects of this type will be discussed in some detail later in the paper.

This paper will discuss some examples of loading effects and methods of minimizing them. The discussion will center first on problems in electrical measurements and then go on to problems in the measurement of temperature, force, pressure, and flow.

## EXAMPLES OF INTERACTION EFFECTS

### Loading Effects in Electrical Measurements

Figure 2 shows some simple examples of loading effects in electrical measurements. The first of these (a), measuring the emf of a standard cell with a voltmeter, is an obvious case of bad practice. The error in emf measurement for this case will be 33 percent and the amount of current drawn will probably damage the cell. To make this measurement properly, one should use a measuring instrument that draws negligible current, i. e., a null-potentiometer.

The circuit shown in 2(b) is commonly used with strain gage transducers in order to obtain a standardized full-scale output signal. In this case, a loading error will result, even if the voltmeter has an infinitely high input resistance, because of the shunting effect of the span adjusting network.

Figure 2(c) shows the measurement of a d-c current using a volt-ohm-milliammeter type test set. In this case, the loading error results from the resistance of the milliammeter circuit, which, for this type of meter, is quite high. A common test set of this type with a 20,000  $\Omega$ /volt sensitivity (a 50  $\mu$ a meter movement) has a sufficiently high resistance that a 1/4 volt drop appears across the meter terminals for full scale current flow.

Figure 2(d) illustrates the point that the shunt capacitance across the input terminals of a measuring instrument must be considered when making a-c measurements. For the case shown, the oscilloscope with a 1 megohm input resistance shunted by a 50 pF capacitor has an input impedance of about 8000 $\Omega$  at 400 kHz. The loading error for the case shown will then be about 7 percent is  $Z_s$  is capacitive.

## Calculation of Loading Effects

Methods of calculating the effect of loading in both voltage and current measurements are given in figure 3. For simplicity these methods are given for d-c measurements. For a-c measurements the resistances of the source, meter, and load must be replaced with their respective a-c impedances. An extension of these methods provides a way of correcting for voltmeter- and ammeter-loading errors by making two measurements. These techniques are described in figures 4 and 5. In each case, a second measurement is made with externally added loading resistors ( $R_{L3}$  and  $R_{M3}$  in figs. 4 and 5, respectively). The choice of the values used for  $R_{L3}$  and  $R_{M3}$  is dependent on the source resistance ( $R_S$ ) in the circuits being measured; the object is to change the loading effect enough to get a measurable change in the indicated variables ( $e_2 - e_1$ ) and ( $i_2 - i_1$ ). Care must be taken, however, to insure that the sources are not damaged by excessive loading. In each case it is also possible to calculate the actual source resistance; these equations are also presented in the figures.

## Determination of Load and Source Resistances

In order to evaluate loading effects, it is necessary to know the input resistances (or impedances) of the instrumentation and the source resistance (or impedance) of the signals to be measured. In the case of commercial instruments, this information can usually be obtained from the manufacturer's literature. Also, these values can be obtained experimentally; however, care must be exercised to insure

that shunt capacitances or series inductances are not overlooked if a-c or transient measurements are being made. For sensitive galvanometers, the measurement of coil resistance must be done carefully to avoid damage to the galvanometer; a recommended method for making this measurement is given in figure 6. Source resistances can be measured by the techniques previously mentioned and shown in figures 4 and 5.

A further caution should be noted in the case of null-balance instruments. Such instruments are characterized by a very high input resistance at null. At off-null conditions, however, the input resistance is variable and has a minimum value much lower than that at null. Figure 7 shows two common types of null-balance instruments, the servo-balanced potentiometer and a potentiometer-type amplifier. The effective input resistances at null and at open loop conditions are shown in the figure. Typical values are also listed. The lower values of off-null input resistance are not commonly specified by manufacturers but are often implied by a recommended maximum source resistance to be used with the instrument. It is the off-null resistance, not the resistance at null, that determines dead-zone, offset, signal-to-noise ratio, reproducibility, or related factors that characterize instrument quality.

### Loading Caused by Paralleled Readout Instruments

In many measuring systems, it is advantageous to use more than one readout instrument. A measurement may be displayed on an indicator in a control room to aid the experiment operator and also routed to recorders and to a digital data system to prepare

it for easy access to a computer. In such cases, loading errors may arise due to the reduced load resistance resulting from having a number of readout instruments in parallel. The lead resistance of long lines between the signal source and the readout instruments will further affect this problem. Figure 8 shows two methods for connecting readout instruments in parallel and states the required conditions for negligible loading errors. This problem is especially critical if one or more of the readout instruments is a null-balance type instrument, because of the lower input resistance of these devices at off-null conditions. In this case, it is usually desirable to add external resistors to increase the isolation of these instruments from the rest of the system. Such resistors are shown in the lower part of figure 8.

The order of magnitude of the loading error in the circuits of figure 8 is given by the ratio of the terms on the left-hand and right-hand sides of the inequalities shown as "required conditions".

### Considerations in Choosing Load Resistance

From the preceding discussion on loading effects, it is apparent that minimum loading is achieved by making  $R_L = \infty$  for voltage measurements and  $R_M = 0$  for current measurements. However, choosing readout instruments solely on this basis may not result in an optimum measuring system. In the case of voltage measurements, choosing  $R_L \rightarrow \infty$  will result in minimum loading effects; it also results in maximum noise voltage and maximum hum voltage. Conversely, choosing  $R_L = R_S$  results in appreciable loading effects but also provides maximum signal-to-noise ratio and maximum signal power transfer. In the case of galvanometer type detectors, higher signal power delivered to the detector results in

a more rugged, more reliable, less position-sensitive, and more accurate instrument. It is for these reasons that manufacturers of volt-ohm-milliammeter type test sets use relatively high resistance meter movements. It is also for these reasons that an appropriate compromise in the choice of  $R_L$  is recommended in designing a measuring system.

### Loading Effects in Temperature Measurement

It was previously stated that interaction effects occur throughout a measuring system. Nonelectrical effects involving the connection of an instrument to an experiment must also be considered. An example of this, the "thermal connection" of a temperature sensor to an experiment, was mentioned earlier. This effect can be thought of as a "thermal loading" effect which is determined by the flow of heat between the experiment, the sensor, and the surrounding environment. Two examples of thermal loading are shown in figures 9 and 10.

Figure 9 shows a temperature sensor used to measure the temperature of a fluid flowing through a duct. In this case heat is transferred from the fluid to the sensor by convection and conduction. Electrical self-heating of a resistance thermometer may be another source of heat transferred to the sensor. Heat is transferred away from the sensor by conduction along the sensor support to the duct wall (assuming the wall is colder than the fluid) and also by conduction along the wires connecting the sensor to the rest of the measuring system. Thermal radiation may also provide a mode of significant heat flow away from the sensor. A schematic diagram of these heat flows is shown at the upper right in figure 9. If the resistance to heat flow between the fluid and the sensor is small compared to the resistance to heat flow between the sensor and the walls and lead wires, the temperature of the sensor will approach the temperature of the fluid and the error due to thermal loading will be minimized.



Some methods of decreasing the thermal loading effect are shown at the bottom of figure 9. Increasing the immersion depth of the sensor increases the length of the support and therefore increases the thermal resistance to heat flow away from the sensor. Greater immersion depth also increases the surface area of the support in contact with the fluid, promoting heat transfer from the fluid to the support and decreasing the temperature gradient along the support.

If a thermocouple may be electrically grounded, welding it to its sheath will improve heat transfer from the surrounding fluid. If the sensor may not be grounded, but must be sheathed for mechanical protection, appropriately-located holes in the sheath will promote convective heat transfer.

Figure 10 shows some examples of surface temperature measurements. At the top of the figure are two methods of mounting thermocouples such that heat conduction along the wires away from the measuring junction is minimized. In each case the wires are routed along an isotherm and with the wires in thermal (but not electrical) contact with the surface. At the bottom are shown two methods of increasing the thermal contact between the surface and the sensor. It should be noted that in the case on the left, the flattened thermocouple junction, the emf of the thermocouple represents the temperature at the point where the two alloys first come into contact, and not the average temperature over the area of the flattened junction, unless the flattened junction is very massive.

### Loading Effects in Force Measurement

Figure 11 shows the loading effect in force measurements using, as an example, the measurement of the weight of a tank and its contents. The sources of the loading effect in this case are the pipes and supports connected to the tank. As shown in the schematic diagram on the right, these pipes and supports act as springs which exert a restraining force

on the tank. The stiffnesses  $K_p$  and  $K_s$  shown on the diagram are the stiffnesses of these springs for deflection in the vertical direction. The stiffness  $K_M$  is the stiffness of the load cell and the force coupling members which connect the load cell to the tank. As shown in the equation at the bottom, the loading effect will be minimized if  $(K_p + K_s) \ll K_M$ . It should be noted that minimizing the loading effect by making  $K_M$  very high results in a measuring system with a greater sensitivity to high-frequency components of building vibration. This result is comparable to making a voltage measurement with a very high  $R_L$ ; the signal-to-noise ratio is decreased.

One further comment is of interest in relation to this example: the loading effect in this case is due to energy storage rather than to power dissipation, as in the other examples discussed earlier. In this case, potential energy (force times deflection) is stored in the load cell and the restraining springs in the system. In the earlier examples, power was lost, either as  $i^2R$  losses in the instrument and source resistances or as heat flow away from the experiment.

### Loading Effect in Measuring Fluctuating Gas Pressure

As an example of a loading effect in pressure measurement, figure 12 shows a duct with a gas flowing through it, where the pressure of the gas is fluctuating sinusoidally around some average level. A pressure transducer is connected via a tube to this duct in order to measure this fluctuating pressure. A loading effect occurs if the system consisting of the connecting tube and transducer volume is unable to accurately transmit the fluctuating pressure to the diaphragm of the transducer. If the damping in this tube-volume system is low, the system can be described as a second-order dynamic system whose resonant frequency is  $f_n$ . The equation for  $f_n$  in figure 12 takes into account both the distributed volume of the tube and the volume in the transducer; if the volume in the transducer

were made zero ( $V = 0$ ), the resonant frequency is that of a quarter-wave-length "organ pipe." If the damping in the system is zero, the measured pressure fluctuation amplitude  $P_M$  is related to the true pressure  $P_T$  by

$$P_M = P_T \left[ \frac{1}{1 - \left(\frac{f}{f_n}\right)^2} \right]$$

If  $f/f_n = 0.2$ , the error due to this loading will then be about 4 percent, and the measured pressure fluctuation amplitude  $P_M$  will be greater than  $P_T$ .

Conversely, if the damping in the system is high (that is, the tube acts like a capillary), the system can be described as a first-order dynamic system characterized by a time constant,  $\tau$ . It can be seen from the equation for  $\tau$  in figure 12 that increasing the volume  $V$  increases the time constant. The relationship between  $P_M$  and  $P_T$  then becomes:

$$P_M = P_T \frac{1}{\sqrt{1 + (2\pi f)^2 \tau^2}}$$

The loading effect will be minimized if

$$(2\pi f)^2 \tau^2 \ll 1$$

and the effect of loading will always be that  $P_M$  is less than  $P_T$ . In both of these cases, it is evident that the loading effect will be minimized by choosing a pressure transducer whose internal volume  $V$  is small compared to the volume  $v$  of the tube.

### Loading Effects in Flow Measurement

An example of a loading effect in flow measurement is shown in figure 13. In this case, a pump supplies a flow rate  $Q_T$  to a load such as a heat exchanger through a closed piping system which, for simplicity, is assumed to have no pressure loss. The head supplied by the pump is  $P_s|_{Q_T}$ , and the load has a pressure drop of  $\Delta P_L|_{Q_T}$ . The notation emphasizes that  $P_s$  and  $\Delta P_L$  will be different if  $Q$  is different. Obviously,  $P_s|_{Q_T} = \Delta P_L|_{Q_T}$ . Now if a flowmeter is added to the system, the pressure drop across the meter causes the flow rate to decrease to  $Q_M$ . The pressure drop across the flowmeter at  $Q_M$  is  $\Delta P_M$ , and for this flow rate a flowmeter resistance term is defined which is  $R_M = (\Delta P_M/Q_M)$ . In order to calculate the loading effect of the flowmeter, the changes in pump head  $P_s|_{Q_T} - P_s|_{Q_M}$  and load pressure drop  $\Delta P_L|_{Q_T} - \Delta P_L|_{Q_M}$  must be determined. Since characteristics of pumps and of many flow systems are nonlinear functions, the changes in  $P_s$  and  $\Delta P_L$  are functions of the operating point. If the pump and load characteristic curves are plotted, these pressure changes can be related to the slopes of the characteristic curves at a flow rate  $Q_T$  (assuming  $(Q_T - Q_M) < Q_T$ ). The pump head can then be written as:

$$P_s = P_s|_{Q_T} - \left. \frac{\partial P_s}{\partial Q} \right|_{Q_T} \cdot (Q_T - Q_M)$$

and the load pressure drop is:

$$\Delta P_L = \Delta P_L \Big|_{Q_T} - \frac{\partial \Delta P_L}{\partial Q} \Big|_{Q_T} \cdot (Q_T - Q_M)$$

Combining these equations with that for the pressure drop across the meter results in an equation for the error due to loading:

$$Q_M = Q_T \left[ 1 - \frac{R_M}{R_M + \frac{\partial \Delta P_L}{\partial Q} \Big|_{Q_T} - \frac{\partial P_s}{\partial Q} \Big|_{Q_T}} \right]$$

It should be noted that the slope of the pump characteristic  $\frac{\partial P_s}{\partial Q} \Big|_{Q_T}$  will be negative; that is, the pump head will increase for a decrease in flow. The result is that  $Q_M$  will be less than  $Q_T$ , and the fractional error due to loading will be the second term inside the square bracket.

### Conclusion


In the preceding discussion, the effects of loading in measurement systems have been described. Methods for determining the loading effect quantitatively and for minimizing such effects have been described. An effort has been made to use practical measurement problems as a basis for the discussion. Two points made in this discussion should be emphasized:

1. Loading effects can occur at all of the interfaces of a measurement system including the interface between the primary sensor and the experiment.

2. Errors due to loading can be minimized by making the effect negligible or by making a correction for an appreciable loading effect. In many cases, the latter approach leads to a more desirable measuring system because of practical considerations such as signal-to-noise ratio.

FIG. 1 INTERACTION EFFECTS CAN ARISE THROUGHOUT

A MEASURING SYSTEM




POSSIBLE INTERACTION PROBLEMS


- ① CONNECTION OF READOUT INSTRUMENTS
- ② EFFECTS BETWEEN PARALLELED READOUT INSTRUMENTS
- ③ EFFECTS OF LINE RESISTANCE
- ④ CONNECTION OF AMPLIFIER
- ⑤ EFFECTS OF SIGNAL CONDITIONING CIRCUITS
- ⑥ ELECTRICAL HEATING OF SENSOR
- ⑦ "THERMAL CONNECTION" OF SENSOR TO EXPERIMENT

FIG. 2 LOADING EFFECTS IN ELECTRICAL MEASUREMENTS


- EXAMPLES




a) STANDARD CELL  
EMF MEASUREMENT  
WITH A VOLTMETER



b) USE OF A SPAN ADJUSTING  
NETWORK ON A STRAIN  
GAGE BRIDGE CIRCUIT




c) MEASUREMENT OF CURRENT  
USING A VOLT-OHM-MILLIAMMETER  
TEST SET



d) AC MEASUREMENTS - EFFECT OF  
SHUNT CAPACITANCE ON LOAD  
IMPEDANCE




FIG. 3 MAGNITUDE OF LOADING EFFECT




$$E_{MEAS} = E_{SOURCE} \frac{R_{LOAD}}{R_{LOAD} + R_{SOURCE}} = E_{SOURCE} \left[ 1 - \frac{R_{SOURCE}}{R_{LOAD} + R_{SOURCE}} \right]$$

*fractional error  
due to loading*

VOLTMETER LOADING



$$I_{TRUE} = \frac{E_{SOURCE}}{R_{LOAD} + R_{SOURCE}}$$




$$I_{MEAS} = \frac{E_{SOURCE}}{R_{LOAD} + R_{SOURCE} + R_{METER}} = I_{TRUE} \left[ 1 - \frac{R_{METER}}{R_{LOAD} + R_{SOURCE} + R_{METER}} \right]$$

*fractional error  
due to loading*

AMMETER LOADING

FIG. 4 A METHOD OF CORRECTING FOR VOLTMETER LOADING ERROR



WITH SWITCH OPEN (1):  $e_1 = \frac{E_s R_{L1}}{R_s + R_{L1}}$   $R_{L1} = \text{VOLT METER RESISTANCE}$


WITH SWITCH CLOSED (2):  $e_2 = \frac{E_s R_{L2}}{R_s + R_{L2}}$   $R_{L2} = \frac{R_{L1} R_{L3}}{R_{L1} + R_{L3}}$

THEN:

$$E_s = e_2 \left[ 1 + \frac{(e_2 - e_1)}{\frac{R_{L2}}{R_{L1}} e_1 - e_2} \right]$$

$$R_s = \frac{e_2 - e_1}{e_1/R_{L1} - e_2/R_{L2}}$$

FIG.5 A METHOD OF CORRECTING FOR AMMETER LOADING ERROR



WITH SWITCH CLOSED (1):  $i_1 = \frac{E_S}{R_S + R_L + R_{M1}}$   $R_{M1} = \text{AMMETER RESISTANCE}$

WITH SWITCH OPEN (2):  $i_2 = \frac{E_S}{R_S + R_L + R_{M2}}$   $R_{M2} = R_{M1} + R_{M3}$


WITH SWITCH CLOSED (1)  
AND NO AMMETER:  $i_T = \frac{E_S}{R_S + R_L}$

THEN:

$$i_T = i_2 \left[ 1 + \frac{i_2 - i_1}{\frac{R_{M1}}{R_{M2}} i_1 - i_2} \right]$$

$$R_S = \frac{i_1 (R_{M1} + R_L) - i_2 (R_{M2} + R_L)}{i_2 - i_1}$$

**FIG. 6** MEASURING THE COIL RESISTANCE OF A SENSITIVE GALVANOMETER




$R_S > 100 R_P$  FOR ERROR  $< 1\%$

WITH SWITCH AT 1: ADJUST  $R_S$  UNTIL METER READS FULL SCALE

WITH SWITCH AT 2: ADJUST  $R_P$  UNTIL METER READS HALF SCALE

THEN,  $R_P = \text{COIL RESISTANCE}$


FIG. 7 NULL - BALANCE INSTRUMENTS



EFFECTIVE INPUT RESISTANCE

AT NULL	$\approx \infty$	$\approx \frac{R_L G_O}{1 + G_C} \quad (\sim 10 M\Omega)$
OPEN LOOP (OFF-NULL)	$\approx R_L \quad (400 \text{ TO } 4000 \Omega)$	$\approx R_L \quad (0.1 M\Omega)$


FIG. 8 LOADING CAUSED BY PARALLELED READOUT INSTRUMENTS



REQUIRED CONDITION:

$$(R_S + R_{LEAD}) \ll \frac{1}{\sum_i \frac{1}{R_{Li}}}$$

LEAD RESISTANCES ——— EXTERNAL RESISTANCES — IF REQUIRED




REQUIRED CONDITION:

$$R_S \ll \frac{1}{\sum_i \frac{1}{R_i}}$$


$R_i$  = TOTAL RESISTANCE OF EACH LOOP, EXCLUDING  $R_S$

FIG.9 FLUID TEMPERATURE MEASUREMENTS - "THERMAL LOADING"



IMPROVEMENTS: TO DECREASE THERMAL LOADING

- INCREASE IMMERSION DEPTH



- IMPROVE "THERMAL CONTACT" OF SENSOR






FIG. 10 SURFACE TEMPERATURE MEASUREMENTS - "THERMAL LOADING"





# FIG. 11 LOADING EFFECTS IN FORCE MEASUREMENT

EXAMPLE: WEIGHING THE CONTENTS OF A TANK




$$F_M = W \left( \frac{K_M}{K_M + K_P + K_S} \right) = W \left[ 1 - \frac{K_P + K_S}{K_M + K_P + K_S} \right]$$

↓ portion of weight due to flexibility

FIG. 12.

# LOADING EFFECT IN MEASURING

## FLUCTUATING GAS PRESSURE



IF THE DAMPING IN THE TUBE IS LOW:

RESONANT FREQUENCY OF THE TUBE & VOLUME  $f_n = \frac{c}{4L} \sqrt{1 + \frac{\pi^2 V}{4 \omega}}$

$$P_M = P_T \left[ \frac{1}{1 - (f/f_n)^2} \right]$$


IF THE DAMPING IN THE TUBE IS HIGH (CAPILLARY TUBE):

TIME CONSTANT OF THE TUBE & VOLUME  $\tau = \frac{128 \nu}{\pi^2 c^2} \left( \frac{L}{D} \right)^2 \left( 1 + \frac{\pi^2 V}{4 \omega} \right)$

$$P_M = P_T \frac{1}{\sqrt{1 + (2\pi f \tau)^2}}$$

c = VELOCITY OF SOUND  
 $\nu$  = KINEMATIC VISCOSITY

FIG. 13 LOADING EFFECT IN FLOW MEASUREMENT



SINCE  $P_3 = \Delta P_L$  WITHOUT FLOWMETER

$P_3 = \Delta P_L + \Delta P_M$  WITH FLOWMETER

$$Q_M = Q_T \left[ 1 - \frac{R_M}{R_M + \frac{\partial \Delta P_L}{\partial Q} \Big| - \frac{\partial P_3}{\partial Q} \Big| Q_T} \right]$$

*fractional error  
due to loading*